

Installation Required in Square Feet

| City | Population | Square Feet | A-2, 3, 4, & 5 | B | E | F-1 & 2 | H-1, 2, 3, 4, & 5 | I-1, 2, 3, & 4 | M | R-1 & 4 | R-2 & 3 | S-1 & 2 | U |
|------------------|------------|-------------|--|--|--|---|-------------------|--|--|--|------------------|--|---------------|
| Cudahy | 18,319 | 0 to 5,000 | 1,000 - 3,000 | 3,000 - 5,000 | 0 | 3,000 - 5,000 | 1,000 | 0 - 5,000 | 3,000 - 5,000 | 0 - 5,000 | State | 3,000 - 5,000 | 3,000 - 5,000 |
| Fitchburg | 22,604 | 0 to 10,000 | 0 | 7,000 - 10,000 | 0 - 10,000 | 7,000 - 10,000 | 0 | 0 - limited | 7,000 - 10,000 | 0 - limited | State | 7,000 - 10,000 | |
| Germentown | 19,189 | 0 - 6,000 | 0 | Fire Resistive 5,000 Non-Fire Resistive 2,500 2 stories or more 0 | Non Fire Resistive 0 Fire-Resistive basement etc. | 5,000 - 6,000 | 0 | 0 | 5,000 - 6,000 | 0 - 4,000 | State Statute | | |
| Grafton | 11,310 | 0 to 12,000 | Theaters and Hall with stages. All others of Non-Fire Resistive located above the 1st floor | Fire Resistive 12,000 Over 1 story over 6,000 Over three stories Non-Fire Resistive 6,000 Over 1 story over 4,000 Over two stories | Fire Resistive- Basements, workshops, labs, stairways, corridors stages, hazardous areas. Non-Fire Resistive 0 | Fire Resistive 12,000 Over 1 story over 6,000 Over three stories Non-Fire Resistive 6,000 Over 1 story over 4,000 Over two stories | 0 | 0 | Fire Resistive 12,000 Over 1 story over 6,000 Non-Fire Resistive 6,000 Over 1 story over 4,000 Over two stories | Non-Fire Resistive 5,000 In basements, storerooms, workrooms furnace rooms halls stairways | State Statute | | |
| Greendale | 14,087 | 0 to 12,000 | Fire Resistive - Stages, under roof of stage, gridirons, dressing rooms etc. Non-Fire Resistive 0 | Fire Resistive 2 - 5 Stories Basements, stairways, corridors. 5 Stories and above 0 Non-Fire Resistive 1 - 2 stories basements, stairways and corridors. 3 stories and above 0 | Fire Resistive- Basements, workshops, stairways, corridors stages, kitchens, hazardous areas. Non-Fire Resistive 0 | Fire Resistive 12,000 Over one story 6,000 Over three stories 0 Non Fire Resistive 6,000 Overone story 4,000 Over two stories | 0 | Fire Resistive - Basements, kitchens, shops, laundries, labs, stairways, corridors etc. Non-Fire Resistive 0 to limited | Fire Resistive 12,000 Over one story 6,000 Over three stories 0 Non-Fire Resistive 6,000 Overone story 4,000 Over two stories | Fire Resistive-Basements, stairways, corridors up to 5 stories. Non-Fire Resistive Basements, stairwahys, corridors up to 2 stories 3 stories and above 0 | State Statute | Fire Resistive 12,000 Over one story 6,000 Over three stories 0 Non-Fire Resistive 6,000 Overone story 4,000 Over two stories | |
| Mequon | 23,468 | 0 to 10,000 | Fire Resistive 0 except auditoriums and foyers. Non-Fire Resistive 0 | Fire Resistive 10,000 Non-Fire Resistive 5,000 | Fire Resistive- Basements, workshops, labs, stairways, corridors, stage, kitchen etc. Non-Fire Resistive 0 | Fire Resistive 10,000 Non-Fire Resistive 5,000 | 0 | 0 | Fire Resistive 10,000 Non-Fire Resistive 5,000 | Fire Resistive- Basements, stairways, corridors up to 1 story. 2 stories or more 0 Non-Fire Resistive 0 | State Statute | | |
| Mt. Pleasant | 24,819 | 0 to 10,000 | 0 | Fire Resistive 10,000 Over 1 story 6,000 Over 2 Stories 0 Non-Fire Resistive 5,000 Over 2 stories 0 | Fire Resistive 10,000 Over 1 story 6,000 Over 2 Stories 0 Non-Fire Resistive 5,000 Over 2 stories 0 | Fire Resistive 10,000 Over 1 story 6,000 Over 2 Stories 0 Non-Fire Resistive 5,000 Over 2 stories 0 | 0 | Fire Resistive 10,000 Over 1 story 6,000 Over 2 Stories 0 Non-Fire Resistive 5,000 Over 2 stories 0 | Fire Resistive 10,000 Over 1 story 6,000 Over 2 Stories 0 Non-Fire Resistive 5,000 Over 2 stories 0 | Fire Resistive 4,800 - 8000 Non-Fire Resistive 0 | State Statute | Fire Resistive 10,000 Over 1 story 6,000 Over 2 Stories 0 Non-Fire Resistive 5,000 Over 2 stories 0 | |
| Muskego | 22,427 | 0 to 12,000 | 3,500 - 10,000 | 5,000 - 12,000 | 0 | 4,000 - 15,000 | 1,000 | 0 - 5,000 | 6,000 - 15,000 | 0 - 5,000 | State | 3,000 - 5,000 | |
| Pewaukee | 12,625 | 0 to 6,000 | 6,000 | 6,000 | Class 1 & 2 Construction - Woodworking, auto, machine shops, and all areas with more than 10 gal. of flammable or comb. Liquids. Buildings of Class 3 - 8 Construction 0 | 6,000 | 0 | 0 | 6,000 | Over 20 occupants 0 | State Statute | | |
| Pleasant Prairie | 18,606 | 0 to 3,500 | 3,500 | 3,500 | 3,500 | 3,500 | 0 | 0 - 3,500 | 3,500 | 0 | State | 3,500 | |
| Port Washington | 10,785 | 0 to 10,000 | 0 | Fire Resistive 10,000 Over 1 story 6,000 Over 3 stories 0 Non-Fire Resistive 8,000 Over 1 story 5,000 Over 3 stories 0 | 0 | Fire Resistive 10,000 Over 1 story 6,000 Over 3 stories 0 Non-Fire Resistive 8,000 Over 1 story 5,000 Over 3 stories 0 | 0 | 0 | Fire Resistive 10,000 Over 1 story 6,000 Over 3 stories 0 Non-Fire Resistive 8,000 Over 1 story 5,000 Over 3 stories 0 | 5,000 | State Statute | 10,000 or over 2 stories | |
| South Milwaukee | 21,373 | 0 to 5,000 | 0 - 5,000 | 3,000 - 5,000 | 0 | 3,000 - 5,000 | 1,000 | 0 - 5,000 | 3,000 - 5,000 | 0 - 5,000 | State | 3,000 - 5,000 | 3,000 - 5,000 |
| Whitefish Bay | 13,914 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | State | 0 | 0 |